



T-IS SELF POWERED CURRENT TRANSDUCER




The Carrel Electrade T-IS current transducer converts a sinusoidal ac current input into a load independent dc current signal capable of driving a number of independent instruments. Power for this unit is derived from the input signal. The output signal is calibrated to rms, based on an arithmetic mean measurement of the rectified input signal, and hence the transducer should be used with undistorted sine waveforms (<1% distortion).

The unit conforms to IEC 60688. In addition it meets the insulation requirements of IEC 60255-5, clauses 5, 6 and 8 as well as the high frequency disturbance test of IEC 60255-22-1 for Class III test voltage.

Specifications

| | |
|-----------------------|--|
| Input | Sinusoidal alternating current Standard nominal range $0 - I_{nom}$: 0 - 1A, 0 - 5A (others on request) Accurate range : 5 - 120% I_{nom} Frequency range : 45 - 50 - 55 - 60 - 65Hz Burden of input at I_{nom} : <1.2VA, <2VA for 20mA output Overload capacity : 2 x I_{nom} continuous : 20 x I_{nom} for 3 seconds |
| Output | Linear current proportional to input Standard nominal outputs : 0-10mA dc <1500Ω load (others on request) : 0-20mA dc <750Ω load Ripple : <1% pk to pk of full span Response time : <250ms 0-90% : <500ms 0-99% |
| Accuracy | : Class 0.5 to IEC 60688 : ±0.5% of nominal output for specified range |
| Isolation | Galvanic isolation between input and output circuits Test voltage : 4kV rms 50Hz for 1 minute Impulse : 5kV 1.2/50μsec waveform |
| Temperature | Operating : -10°C to +20°C to +50°C Storage : -20°C to +70°C |
| EMC Compliance | : AS/NZS 61000.6.3:2012 |
| Housing | Self extinguishing grey polycarbonate to IP40 snap mounting on top hat rail DIN EN 50022-35 |
| Terminals | Tinned steel pozi-drive M3 screws with captive square washers suitable for 2 x 2.5mm ² conductors (max). Optional terminal covers raise rating from IP10 to IP20 |

Housing & Connection Diagrams



CARREL ELECTRADE LTD

MANUFACTURERS, IMPORTERS AND DISTRIBUTORS OF ELECTRICAL ENGINEERING PRODUCTS
 POSTAL ADDRESS: P O BOX 11078, ELLERSLIE 1542, AUCKLAND NEW ZEALAND
 FACTORY AND OFFICE: 661 GREAT SOUTH ROAD, PENROSE 1061
 TELEPHONE: +64-9-525 1753 FACSIMILE: +64-9-525 1756
 CHRISTCHURCH BRANCH: 73B BRISBANE STREET, SYDENHAM
 TELEPHONE: 03-366 1242 FACSIMILE: 03-379 1991
 EMAIL: sales@carrel-electrade.co.nz WEB: www.carrel-electrade.co.nz